



RES.CURRENT OP.CIRCUIT BREAKER TYPE AC WS  
D=55MM 25A 3+N-POL IFN 30MA 400V 4MW





Similar to image

**Technical data:**

<b>mounting position</b>		any
<b>Design of the product</b>		Instantaneous
<b>Supply voltage / for AC / rated value</b>	V	400
<b>Resistance against the impulse current / rated value</b>	kA	1
<b>Ambient temperature</b>	°C	-5 ... +45
<b>Ambient temperature</b> • during storage	°C	-40 ... +60
<b>Mechanical operating cycles as operating time / typical</b>		10,000
<b>Overvoltage class</b>		III
<b>Supply voltage / for testing equipment / minimum</b>	V	100
<b>Protection against electrical shock</b>		Finger and back-of-hand safe
<b>Position / of power supply cord</b>		top or bottom
<b>Tightening torque</b> • with screw-type terminals	N·m	2.5 ... 3
<b>Section de conducteur raccordable</b> • solid	mm <sup>2</sup>	1.5 ... 25
• multibrin	mm <sup>2</sup>	1.5 ... 25
<b>Product feature</b>		

• [not supplied - silicon-free]	Yes
• halogen-free	Yes
<b>Number of test cycles / for environmental testing / in accordance with IEC 60068-2-30</b>	28

### Certificates/approvals:

General Product Approval		Declaration of Conformity		
 GOST	<a href="#">other</a>	 VDE	 ÖVE	 EG-Konf.
Test Certificates		other		
<a href="#">Special Test Certificate</a>	<a href="#">Type Test Certificates/Test Report</a>	<a href="#">Environmental Confirmations</a>		

### Further information:

#### Information- and Downloadcenter (Catalogs, Brochures,...)

<http://www.siemens.com/lowvoltage/catalogs>

#### Industry Mall (Online ordering system)

<http://www.siemens.com/lowvoltage/mall>

#### Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

<http://support.automation.siemens.com/WW/view/en/5SM1342-0/all>

#### Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

[http://www.automation.siemens.com/bilddb/cax\\_en.aspx?mlfb=5SM1342-0](http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SM1342-0)

#### CAX-Online-Generator

<http://www.siemens.com/cax>

last change:

Dec 31, 2012